

DESIGN DATA:

1. EARTH COVER = 5 FEET MAX

2. ALLOWABLE WHEEL LOAD = 8000 LB MAX 3. CONCRETE MINIMUM COMPRESSIVE STRENGTH = 5,090 PSI @ 28 DAYS

4. LIFTING HOOKS ARE $\frac{5}{8}$ " DIAMETER, ASTM A36COLD ROLLED STEEL

5. SEPTIC TANK LID IS REINFORCED WITH #3 REBAR SPACED AT 12" OC GRID.

6. SEPTIC TANK BOTTOM AND SIDES ARE REINFORCED WITH 6 X 6 W8.0 X W8.0 WELDED WIRE FABRIC. 7. ALL CONCRETE SURFACES ABOVE THE LIQUID LEVEL ARE COATED WITH AIRLESS ASPHALT.

CASTING WEIGHTS

WEIGHT OF LID: WEIGHT OF TANK: 8,493.5 LBS TOTAL CASTING WEIGHT: 11,537.4 LBS

(2) COMPARTMENT TANK CAPACITY:

FIRST COMPARTMENT CAPACITY = 655 GALLONS 10.6 GALLONS PER INCH

SECOND COMPARTMENT CAPACITY = 339 GALLONS 5.5 GALLONS PER INCH

STORAGE CAPACITY = 999 GALLONS TOTAL VOLUME = 1198 GALLONS

1211 North Weston Street P.O. BOX 70 RENSSELAER, INDIANA 47978 phone: (219) 866-5063 (800) 240-5123

fax: (219) 866-3894

KEYNOTE INDEX

- 1 20" DIAMETER MANHOLE OPENING
- 2 HIGH PRESSURE CLOSED END BOOT SEAL
- 3 MASTIC ROPE 4 SANITARY TEE AT INLET & OUTLET
- 5 | 5" DIAMETER LIFTING HOOKS
- 6 6" DIAMETER INLET
- 7 6" DIAMETER OUTLET
- 8 12" EXTENSION AT INLET
- 9 24" EXTENSION AT OUTLET
- 10 FLEXIBLE, NON-CORROSIVE POLYPROPYLENE GAS BAFFLE BY TUF-TITE AFFIXED WITH STAINLESS STEEL SCREWS
- 11 CONCRETE GRADE RING (AS NECESSARY)
- 12 CAST FRAME & COVER (NOT INCLUDED)
- 13 THREE (3) 6" DIAMETER HOLES THROUGH INTERIOR WALL

R-000

MANUFACTURER'S

DETAIL DRAWING

1000 GALLON (2) COMPARTMENT

TRAFFIC RATED

DRAWN BY:

1000 GAL- DUAL- TR.DW

* ALL RENSSELAER SEPTIC TANKS ARE MONOLITHICALLY POURED *