

3. CONCRETE MINIMUM COMPRESSIVE STRENGTH = 5,090 PSI @ 28 DAYS

4. LIFTING HOOKS ARE §" DIAMETER, ASTM A36COLD ROLLED STEEL SEPTIC TANK LID IS REINFORCED WITH #3 REBAR SPACED AT 12" OC GRID.

SEPTIC TANK BOTTOM AND SIDES ARE REINFORCED WITH 6 X 6 W8.0 X W8.0 WELDED WIRE FABRIC. 7. ALL CONCRETE SURFACES ABOVE THE LIQUID LEVEL ARE COATED WITH AIRLESS ASPHALT.

SECOND COMPARTMENT CAPACITY = 683 GALLONS

1211 North Weston Street P.O. BOX 70 RENSSELAER, INDIANA 47978 phone: (219) 866-5063 (800) 240-5123

fax: (219) 866-3894

KEYNOTE INDEX 1 20" DIAMETER MANHOLE OPENING

2 HIGH PRESSURE CLOSED END BOOT SEAL

3 MASTIC ROPE 4 SANITARY TEE AT INLET & OUTLET

5 | 5" DIAMETER LIFTING HOOKS 6 6" DIAMETER INLET

7 6" DIAMETER OUTLET

8 12" EXTENSION AT INLET 9 24" EXTENSION AT OUTLET

10 FLEXIBLE, NON-CORROSIVE POLYPROPYLENE GAS BAFFLE BY TUF-TITE AFFIXED WITH STAINLESS STEEL SCREWS

11 CONCRETE GRADE RING (AS NECESSARY)

12 CAST FRAME & COVER (NOT INCLUDED)

13 THREE (3) 6" DIAMETER HOLES THROUGH INTERIOR WALL

2000 GALLON (2) COMPARTMENT TRAFFIC RATED

R-000

MANUFACTURER'S

DETAIL DRAWING

DRAWN BY:

2000 GAL- DUAL- TR.DW